
EVK203/EVK213/EVK223/EVK253 Digital thermostats for ventilated refrigerating units


GETTING STARTED 1.1 Important

Read these instructions carefully before installing and using the instrument and follow all additional information for installation and electrical connection; keep these instructions close to the instrument for future

1.2 Installing the instrument

Panel mounting, with click brackets (supplied by the builder); dimen-






Additional information for installation


- 59.0 (2.322) is the maximum depth with screw terminal blocks
- 83.0 (3.267) is the maximum depth with extractable terminal blocks • the panel thickness must not be higher than 8.0 mm (0.314 in)
- working conditions (working temperature, humidity, etc.) must be between the limits indicated in the technical data
- do not install the instrument close to heating sources (heaters, hot air ducts, etc.), devices provided with big magnetos (big speakers, etc.), locations subject to direct sunlight, rain, humidity, dust, mechanical vibrations or bumps
- according to the safety legislation, the protection against electrical parts must be ensured by a correct installation of the instrument; the parts that ensure the protection must be installed so that you can not remove them if not by using a tool.


1.3 Wiring diagram


With reference to the wiring diagrams

- port 1 (by request) is the serial port for the communication with the supervision system (through a serial interface, via TTL, with MODBUS communication protocoll or with the programming key: the port must not be used at the same time for the same purposes
- port 2 (by request, not available in EVK223 and EVK253 with power supply 230 VAC and 115 VAC) is the port for the communication with the remote indicator; the indicator shows the quantity you have set









Additional information for electrical connection:

- do not operate on the terminal blocks with electrical or pneumatic
- if the instrument has been moved from a cold location to a warm one, the humidity could condense on the inside: wait about an hour before supplying it
- test the working power supply voltage, working electrical frequency and working electrical power of the instrument: they must correspond with the local power supply
- disconnect the local power supply before servicing the instrument
- do not use the instrument as safety device
- for repairs and information on the instrument please contact Evco
- sales network

2 USER INTERFACE

2.1 Turning on/off the instrument

To turn on the instrument you have to supply it; to turn it off it is enough

Through the digital input (only EVK213 and EVK223) it is also possible to turn off the instrument at a distance (or turn off the instrument via software; in this case the instrument remains connected to the power supply and the regulators are turned off).

- If the instrument is turned on, during the normal operation the display will show the quantity you have set with parameter P5:
- if P5 = 0, the display will show the cabinet temperature
- if P5 = 1, the display will show the working setpoint
- if P5 = 2, the display will show the evaporator temperature
- if P5 = 3, the display will show "cabinet temperature evaporator tem-
- if P5 = 4, the display will show the condenser temperature (only

2.3 Showing the cabinet temperature

- make sure the keyboard is not locked and no procedure is running
- press 2 s: the display will show the first available label
- press ♠ or ▼ to select "Pb1"
- press set
- To guit the procedure:
- press set or do not operate 60 s
- lacksquare press $\begin{tabular}{|c|c|c|c|}\hline \bullet & press \\\hline \bullet & pre$ set with parameter P5 or do not operate 60 s.

2.4 Showing the evaporator temperature

- make sure the keyboard is not locked and no procedure is running
- press 🔻 2 s: the display will show the first available label ■ press 🗽 or 🔻 to select "Pb2"
- press set
- To quit the procedure:
- press set or do not operate 60 s

- press 🗽 or 🔻 as long as the display shows the quantity you have
- If the evaporator probe is not enabled (parameter P3 = 0), the label "Pb2" will not be shown.

2.5 Showing the condenser temperature (only EVK253)

- make sure the keyboard is not locked and no procedure is running
- press ▼ 2 s: the display will show the first available label ■ press 🔊 or 🔻 to select "Pb3"
- press set
- To quit the procedure:
- press set or do not operate 60 s ■ press (本等) or vas long as the display shows the quantity you have set with parameter P5 or do not operate 60 s.
- If the condenser probe is not enabled (parameter P4 = 0), the label "Pb3" will not be shown

2.6 Activating the defrost by hand

- make sure the keyboard is not locked and no procedure is running.
- If the function of the evaporator probe is the one of defrost probe (parameter P3 = 11 and to the defrost activation the evaporator temperature is above the one you have set with parameter d2, the defrost will not be activated

2.7 Locking/unlocking the keyboard

- To lock the keyboard:
- make sure no procedure is running
- press set and ▼ 2 s: the display will show "Loc" 1 s. If the keyboard is locked, you will not be allowed to:
- show the evaporator temperature
- show the condenser temperature (only EVK253)
- activate the defrost by hand
- modify the working setpoint with the procedure related in paragraph 3.1 (you also can modify the working setpoint through parameter SP).
- These operations provoke the visualization of the label "Loc" 1 s.
- press set and ▼ 2 s: the display will show "UnL" 1 s.
- 2.8 Silencing the buzzer
- make sure no procedure is running
- press a button (the first pressure of the button does not provoke its

3.1 Setting the working setpoint

- make sure the keyboard is not locked and no procedure is running
- press set LED 🗱 will flash
- press ▲ For in 15 s; also look at parameters r1, r2 and r3
- press set or do not operate 15 s.
- You also can modify the working setpoint through parameter SP.

3.2 Setting configuration parameters To gain access the procedure:

make sure no procedure is running

- press ▲ ⊕ and ▼ 4 s: the display will show "PA"
- press ▲ ⊕ or ▼ in 15 s to set "-19"
- press set or do not operate 15 s
- press ▲ and ▼ 4 s: the display will show "SP"
- press ♠♠ or ▼
- press ♠ or ▼ in 15
- press set or do not operate 15 s

- press ♠ and ▼ 4 s or do not operate 60 s.
- Switch off/on the power supply of the instrument after the modification of the parameters.

3.3 Restoring the default value of configuration para

- make sure no procedure is running • press ♠ and ▼ 4 s: the display will show "PA"
- press ♠ or ▼ in 15 s to set "**743**"
- r do not operate 15 s
- press and ▼ 4 s: the display will show "dEF"
- press ▲ or ▼ in 15 s to set "149"
- press set or do not operate 15 s: the display will show "dEF" flash-
- ing 4 s, after which the instrument will quit the procedure switch off/on the power supply of the instrument

Make sure the default value of the parameters is appropriate, in particular if the probes are PTC probes.

4 SIGNALS 4.1 Signals

LED defrost

	1110 1111110
₩	LED compressor
	if it is lit, the compressor will be turned on
	if it flashes:
	l

if it is lit, the defrost will be running

• the modification of the working setpoint will be running a compressor protection will be running (parameters CO) C1. C2 and i7)

- the defrost will be required but a compressor protection will be running (parameters C0, C1 and C2)
- the heating of the freezing fluid will be running (parameter dA)

LED evaporator fan

if it is lit, the evaporator fan will be turned on if it flashes, the after dripping evaporator fan delay will be

LED alarm

- f it is lit, an alarm will be running
- Celsius degree (parameter P2)
- Fahrenheit degree (parameter P2)
- the quantity to show is not available (for example because

5.1 Alarms

CODE MEANING Lower temperature alarm

- check the temperature joined to the alarm
 - look at parameters A0, A1 and A2
- Upper temperature alarm
 - check the temperature joined to the alarm look at parameters A3, A4 and A5
- parameter i0 has value 2 or 31
- the input
- Effects:
- Multipurpose input alarm (only EVK213 and EVK223 and if

 - look at parameters i1 and i5
 - Effects:
- - Remedies:
 - the multipurpose input
 - switch off/on the power supply of the instrument
- the regulators will be turned off сон

 - check the condenser temperature
 - no effect

 - check the condenser temperature cut off the power supply of the instrument and clean the
 - condense look at parameter C7
- When the cause that has provoked the alarm disappears, the instrument restores the normal operation, except for the instrument locked alarm (code "iSd") and the compressor locked alarm (code "CSd") that

need you switch off/on the power supply of the instrument.

6.1 Internal diagnostics

- Cabinet probe error Remedies:

- the dripping will be running (parameter d7)
- running (parameter F3)
- LED Celsius dearee f it is lit, the unit of measure of the temperatures will be
- LED Fahrenheit degree if it is lit, the unit of measure of the temperatures will be
- CODE MEANING Loc the keyboard and/or the working setpoint are locked (pa ameter r3); also look at paragraph 2.7
- the probe is not enabled)

5 ALARMS

- no effect
- no effec Door switch input alarm (only EVK213 and EVK223 and if
- check the reasons that have provoked the activation of
- look at parameters i0 and i1 • the effect you have set with parameter i0
- parameter i0 has value 01
- check the reasons that have provoked the activation of the input
- if parameter i5 has value 3, there will be no effect. if parameter i5 has value 4, the compressor will be turned
 - Instrument locked alarm (only EVK213 and EVK223 and if parameter i0 has value 01
 - check the reasons that have provoked the activation of
- look at parameters i1, i5, i7, i8 and i9
- look at parameter C6
 - Compressor locked alarm (only EVK253)
- the compressor and the evaporator fan will be turned off

6 INTERNAL DIAGNOSTICS

CODE MEANING

- look at parameter P0
- check the integrity of the probe check the connection instrument-probe

- the compressor activity will depend on parameters C4 and
- Evaporator probe error
 - Remedies
 - the same you saw in the previous case but related to the evaporator probe
 - Effects:
 - if parameter P3 has value 1, the defrost will last the time you will have set with parameter d3
 - if parameter P3 has value 1 and parameter d8 has value 2, the instrument will work as if parameter d8 had value 0 if parameter F0 has value 3 or 4, the instrument will work
- as if the parameter had value 2 Pr3
 - Condenser probe error (only EVK253) emedies: the same you saw in the previous case but related to the
 - condenser probe Effects: • the overheated condenser alarm (code "COH") and the

compressor locked alarm (code "CSd") will never be activated When the cause that has provoked the alarm disappears, the instru-

ment restores the normal of

7 TECHNICAL DATA 7.1 Technical data

Box: self-extinguishing grey

Frontal protection: IP 65. Connections: screw terminal blocks (power supply, inputs and outputs), 6 poles connector (serial port; by request), 4 poles connector (to the remote indicator; by request, not available in EVK223 and EVK253 with power supply 230 VAC and 115 VAC); extractable terminal blocks

(power supply, inputs and outputs) by reques Working temperature: from 0 to 55 °C (32 to 131 °F, 10 \dots 90% of

Power supply EVK203 and EVK253: 230 VAC, 50/60 Hz, 3 VA (approximate); 115 VAC or 12-24 VAC/DC or 12 VAC/DC by re-Power supply EVK213: 12 VAC/DC, 50/60 Hz, 3 VA (approximate);

Power supply EVK223: 230 VAC, 50/60 Hz, 3 VA (approximate);

probe and evaporator probel for PTC/NTC probes

115 VAC by request Alarm buzzer: by request Measure inputs EVK203, EVK213 and EVK223: 2 (cabinet

Measure inputs EVK253: 3 (cabinet probe, evaporator probe and condenser probe) for PTC/NTC probes Digital inputs (only EVK213 and EVK223): 1 (multipurpose/

door switch) for NO/NC contact (free of voltage, 5 V 1 mA). Working range: from -50.0 to 150.0 °C (-50 to 300 °F) for PTC probe, from -40.0 to 105.0 °C I-40 to 220 °FI for NTC probe.

- Resolution: 0.1 °C/1 °C/1 °F Digital outputs: 3 relays: - compressor relay: 16 res. A @ 250 VAC (NO contact) in EVK203, EVK213 and EVK253 (this last
 - with power supply 12 VAC/DC and 12-24 VAC/DCI: 8 res. A @ 250 VAC otherwise • defrost relay: 8 res. A @ 250 VAC (change-over

• evaporator fan relay: 8 res. A @ 250 VAC (NO

contact) in EVK203, EVK213 and EVK253 (this last

with power supply 12 VAC/DC and

tocol) or with the programming key; by request

with power supply 230 VAC and 115 VAC

The maximum current allowed on the loads is 10 A Serial port: port for the communication with the supervision system (through a serial interface, via TTL, with MODBUS communication pro-

Further communication ports: port for the communication with the remote indicator; by request, not available in EVK223 and EVK253

12-24 VAC/DC); 5 res. A @ 250 VAC otherwise.

	orking	MAX.	ints U.M.	DEF.	WORKING SETPOINTS
	r1	r2	°C/°F (1)	0.0	working setpoint
			paramete		hyenymic cerenculars
PARAM. SP	MIN.	MAX.	U.M. °C/°F (1)	DEF.	WORKING SETPOINTS working setpoint
PARAM.		MAX.	U.M.	DEF.	MEASURE INPUTS
A1	-25.0	25.0	°C/°F (1)	0.0	cabinet probe offset
A2	-25.0	25.0	°C/°F (1)	0.0	evaporator probe offset
CA3	-25.0	25.0	°C/°F (1)	0.0	condenser probe offset (only EVK253)
0	0	1		1	kind of probe
					0 = PTC = NTC
21	0	1		1	decimal point Celsius degree (for the quantity to show during the normal operation)
					1 = YES
2	0	1		0	unit of measure temperature (2)
					0 = °C
3	0	2		1	1 = °F evaporator probe function
,	0				0 = probe not enabled
					1 = defrost probe and thermostat probe for the evaporator fan
					2 = thermostat probe for the evaporator fan
4	0	1		1	enabling the condenser probe (only EVK253)
\r			1		1 = YES
25	0	4		0	quantity to show during the normal operation
					0 = cabinet temperature 1 = working setpoint
					2 = evaporator temperature
					3 = "cabinet temperature - evaporator temperature"
					4 = condenser temperature (only EVK253, not visible otherwise)
ARAM.	MIN.	MAX.	U.M.	DEF.	MAIN REGULATOR
0	0.1	15.0	°C/°F (1)	2.0	working setpoint differential
1	-99.0	r2	°C/°F (1)	-50.0	minimum working setpoint
2	r1	99.0	°C/°F (1)	50.0	maximum working setpoint
3	0	1		0	locking the working setpoint modification (with the procedure related in paragraph 3.1) 1 = YES
4	0.0	99.0	°C/°F (1)	0.0	temperature increase during function Energy Saving (only EVK213 and EVK223); also look at i5
ARAM.		MAX.	U.M.	DEF.	COMPRESSOR PROTECTIONS
0	0	240	min	0	compressor delay since you turn on the instrument
1	0	240	min	5	minimum time between two activations in succession of the compressor; also compressor delay si
					the end of the cabinet probe error (3)
2	0	240	min	3	minimum time the compressor remains turned off
:3 :4	0	240	S:-	0	minimum time the compressor remains turned on
- 4 25	0	240 240	min min	10	time the compressor remains turned off during the cabinet probe error; also look at C5 time the compressor remains turned on during the cabinet probe error; also look at C4
<u> </u>	0.0	199.0	°C/°F (1)	80.0	condenser temperature above which the overheated condenser alarm is activated (only EVK253) (
7	0.0	199.0	°C/°F (1)	90.0	condenser temperature above which the compressor locked alarm is activated (only EVK253)
[8	0	15	min	1	compressor locked alarm delay (only EVK253) (5)
PARAM.		MAX.	U.M.	DEF.	DEFROST
10	0	99	h	8	defrost interval; also look at d8 (6)
11	0	1		0	0 = the defrost at intervals will never be activated kind of defrost
11	0	'		0	0 = electric defrost
					1 = hot gas defrost
12	-99.0	99.0	°C/°F (1)	2.0	defrost cutoff temperature (only if P3 = 1)
13	0	99	min	30	defrost duration if P3 = 0 or 2; defrost maximum duration if P3 = 1
	L		<u>L</u>		0 = the defrost will never be activated
14	0	1		0	defrost when you turn on the instrument
15		000			1 = YES
15	0	99	min	0	defrost delay when you turn on the instrument (only if d4 = 1); also look at i5
16	U	['		1	temperature shown during the defrost 0 = cabinet temperature
					1 = if to the defrost activation the cabinet temperature is below "working setpoint + r0", at most "w
					ing setpoint + r0"; if to the defrost activation the cabinet temperature is above "working setpoi
					r0", at most the cabinet temperature to the defrost activation (7)
		15	min	2	dripping duration
	0	-		0	kind of defrost interval
	0	2		0	
		-			0 = the defrost will be activated when the instrument will have remained turned on the time d0
		-			0 = the defrost will be activated when the instrument will have remained turned on the time $d0$ 1 = the defrost will be activated when the compressor will have remained turned on the time $d0$
		-			0 = the defrost will be activated when the instrument will have remained turned on the time $d0$ 1 = the defrost will be activated when the compressor will have remained turned on the time $d0$ 2 = the defrost will be activated when the evaporator temperature will have remained below the t
18		-	°C/°F (1)	0.0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the t
18	0	2			0 = the defrost will be activated when the instrument will have remained turned on the time $d0$ 1 = the defrost will be activated when the compressor will have remained turned on the time $d0$ 2 = the defrost will be activated when the evaporator temperature will have remained below the t
19 14	-99.0 0	99.0	°C/°F (1)	0.0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2)
is ig ia aram.	-99.0 0 MIN.	99.0 99 MAX.	°C/°F (1) min U.M.	0.0 0 DEF:	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the temperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS
117 118 119 11A 2ARAM.	-99.0 0	99.0	°C/°F (1) min	0.0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm
118 119 11A PARAM.	-99.0 0 MIN.	99.0 99 MAX.	°C/°F (1) min U.M.	0.0 0 DEF:	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 [8] evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) [9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature
118 119 11A PARAM.	-99.0 0 MIN.	99.0 99 MAX.	°C/°F (1) min U.M.	0.0 0 DEF:	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the temperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10)
19 14 14 10	-99.0 0 MIN.	99.0 99 MAX. 2	°C/°F (1) min U.M.	0.0 0 DEF.	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARNS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11)
118 119 11A PARAM.	-99.0 0 MIN.	99.0 99 MAX.	°C/°F (1) min U.M.	0.0 0 DEF:	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4)
19 1A 2ARAM.	-99.0 0 MIN. 0	99.0 99 MAX. 2	°C/°F (1) min U.M	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARNS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11)
19 1A 2ARAM.	-99.0 0 MIN. 0	99.0 99 MAX. 2	°C/°F (1) min U.M	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (10) EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4) kind of lower temperature alarm
19 19 14 14 14 14 14 14 14 14 14 14 14 14 14	-99.0 0 MIN. 0	99.0 99 MAX. 2	°C/°F (1) min U.M	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4) kind of lower temperature alarm 0 = alarm not enabled 1 = relative to the working setpoint (or "working setpoint - A1"; consider A1 without sign) 2 = absolute (or A1)
19 14A 2ARAM.	-99.0 0 MIN. 0	99.0 99 MAX. 2	°C/°F (1) min U.M	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4) kind of lower temperature alarm 0 = alarm not enabled 1 = relative to the working setpoint (or "working setpoint - A1"; consider A1 without sign) 2 = absolute (or A1) temperature joined to the upper temperature alarm (only EVK253, not visible = 0 otherwise)
99 NA NARAM.	-99.0 0 MIN. 0	99.0 99 MAX. 2 99.0 2	°C/°F (1) min U.M °C/°F (1)	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the toperature d9 the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2) minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4) kind of lower temperature alarm 0 = alarm not enabled 1 = relative to the working setpoint (or "working setpoint -A1"; consider A1 without sign) 2 = absolute (or A1) temperature joined to the upper temperature alarm (only EVK253, not visible = 0 otherwise) 0 = cabinet temperature
99 NA NARAM.	-99.0 0 MIN. 0	99.0 99 MAX. 2 99.0 2	°C/°F (1) min U.M °C/°F (1)	0.0 0 DEF: 0	0 = the defrost will be activated when the instrument will have remained turned on the time d0 1 = the defrost will be activated when the compressor will have remained turned on the time d0 2 = the defrost will be activated when the evaporator temperature will have remained below the time d0 (8) evaporator temperature above which the count of the defrost interval is suspended (only if d8 = 2 minimum time the compressor must be remained turned on (to the defrost activation) in order that defrost can be activated (only if d1 = 1) (9) ALARMS temperature joined to the lower temperature alarm 0 = cabinet temperature 1 = evaporator temperature (10) 2 = condenser temperature (only EVK253, not visible otherwise) (11) temperature below which the lower temperature alarm is activated; also look at A0 and A2 (4) kind of lower temperature alarm 0 = alarm not enabled 1 = relative to the working setpoint (or "working setpoint - A1"; consider A1 without sign) 2 = absolute (or A1) temperature joined to the upper temperature alarm (only EVK253, not visible = 0 otherwise)

2 = absolute (or A4)

temperature alarm delay

240 min

1 = relative to the working setpoint (or "working setpoint + A4"; consider A4 without sign)

120 upper temperature alarm delay since you turn on the instrument (only if A3 = 0)

A8	0	240	min	15	upper temperature alarm delay since the end of the after dripping evaporator fan delay (only if $A3 = 0$) (12)				
A9	0	240	min	15	upper temperature alarm delay since the deactivation of the door switch input (only EVK213 and EVK223) (13)				
PARAM.	MIN.	MAX.	U.M.	DEF.	EVAPORATOR FAN				
F0	0	4		1	evaporator fan activity during the normal operation				
					0 = turned off				
					1 = turned on				
					2 = according to the compressor				
					3 = according to F1 (14)				
		00.0	0.5.05.44		4 = turned off if the compressor is turned off, according to F1 if the compressor is turned on (14)				
F1 F2	-99.0	99.0	°C/°F (1)	-1.0	evaporator temperature above which the evaporator fan is turned off (only if F0 = 3 or 4) (4)				
FZ	0	2		0	evaporator fan activity during the defrost and the dripping				
					0 = turned off				
					1 = turned on				
F3	0	15	min	2	2 = according to F0 duration of the after dripping evaporator fan delay				
PARAM.	-	MAX.	U.M.	DEF.	DIGITAL INPUTS (only EVK213 and EVK223)				
iO	0	3	O.IVI.	2	kind of digital input				
10				_	0 = <u>MULTIPURPOSE INPUT</u> - in this case look at parameters i1, i5, i7, i8 and i9				
					1 = RESERVED				
					2 = DOOR SWITCH INPUT - in this case look at parameters i1, i2 and i3; the activation of the input will				
					turn off the evaporator fan (at most the time i3 or as long as the input will be deactivated)				
					$3 = \frac{\text{DOOR SWITCH INPUT}}{\text{INPUT}}$ - in this case look at parameters i1, i2 and i3; the activation of the input will				
					turn off the compressor and the evaporator fan (at most the time i3 or as long as the input will be				
					deactivated) (15)				
i1	0	2		0	kind of contact digital input				
1.1		ļ^		J	0 = NO (the input will be active if you close the contact)				
					1 = NC (the input will be active if you close the contact)				
					2 = input not enabled				
i2	-1	120	min	30	delay to signal the door switch input alarm				
12	ļ '	120	1	30	-1 = no signal				
i3	-1	120	min	15	maximum duration of the effect provoked by the activation of the door switch input				
15	l '	120	1	13	-1 = the effect will last as long as the input will be deactivated				
i5	0	5		3	effect provoked by the activation of the multipurpose input				
					0 = no effect				
					1 = <u>SYNCHRONIZING THE DEFROSTS</u> - spent the time d5 the defrost will be activated (16)				
					2 = <u>ACTIVATING THE ENERGY SAVING</u> - function Energy Saving will be activated (as long as the input				
					will be deactivated); also look at r4 (16)				
					$3 = \frac{\text{ACTIVATING THE EXTERNAL ALARM}}{\text{ACTIVATING THE EXTERNAL ALARM}}$ spent the time i7 the display will show the code " iA " flashing				
					and the buzzer will be activated (as long as the input will be deactivated)				
					4 = <u>ACTIVATING THE MANOSTAT</u> - the compressor will be turned off, the display will show the code " iA "				
					flashing and the buzzer will be activated (as long as the input will be deactivated); also look at i7, i8				
					and i9				
					5 = <u>TURNING OFF THE INSTRUMENT</u> - the instrument will be turned off via software (as long as the				
					input will be deactivated); also look at CO, d4 and A6				
i7	0	120	min	0	if i5 = 3, delay to signal the multipurpose input alarm				
		1.20		-	if i5 = 4, compressor delay since the deactivation of the multipurpose input (17)				
i8	0	15		0	number of multipurpose input alarms such as to provoke the instrument locked alarm (only if i5 = 4)				
		-			0 = alarm not enabled				
i9	1	999	min	240	time without multipurpose input alarms in order that the alarm counter is cleared (only if i5 = 4)				
PARAM.	MIN.	MAX.	U.M.	DEF.	SERIAL NETWORK (MODBUS)				
LA	1	247		247	instrument address				
Lb	0	3		2	baud rate				
					0 = 2,400 baud				
					1 = 4,800 baud				
					2 = 9,600 baud				
					3 = 19,200 baud				
LP	0	2		2	parity				
					0 = none				
					1 = odd				
					2 = even				
(1)	the un	it of me	sure denen	ds on n	arameter P2				
(2)					the regulators appropriately after the modification of the parameter P2				
(3)		-			elay since the end of the cabinet probe error will however be 2 min				
(4)			of the parar						
(5)					nt) the condenser temperature is above the one you have set with parameter C7, parameter C8 will have				
	no effe	-							
(6)			stores the co	ount of t	he defrost interval every 30 min; the modification of parameter d0 has effect since the end of the previous				
. /					ion of a defrost by hand				
(7)					eration as soon as the after dripping evaporator fan delay ends and the cabinet temperature falls below				
. /		-			/ (or if a temperature alarm arises)				
(8)				, ,	ne instrument will work as if parameter d8 had value 0				
(9)					ration of the activation of the compressor is shorter than the time you have set with parameter dA, the				
. /					ned on the fraction of time required to complete it				
(10)					strument will work as if parameter A0 had value 0				
(11)					·				
(12)	if parameter P4 has value 0, the instrument will work as if parameter had value 0 during the defrost, the dripping and the evaporator fan delay the temperature alarms are not enabled, on condition that they have arisen								
(14)	after the activation of the defrost								
(13)					vitch input the upper temperature alarm is not enabled, on condition that it has arisen after the activation				
1,21	of the input								



of the input

the effect is not signalled

if parameter P3 has value 0, the instrument will work as if parameter F0 had value 2

dripping evaporator fan delay, the activation will provoke no effect on the compressor

make sure the time you have set with parameter i7 is shorter than the one you have set with parameter i9.

the compressor is turned off spent 10 s since the activation of the input; if the input is activated during the defrost, the dripping or the after

The instrument must be disposed according to the local legislation about the collection for electrical and electronic equipment.